

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make: Baldor
Serial No.: M05A071172-1

Engine Make & Model: CUMMINS GTA855G3
Serial No.: 25300238

Rating: kW 250 Volts 208 Amps 693 Hertz 60 P.F. 1.0

Test Date: <u>10/06/16</u>	5 min	15 min	30 min	45 min
% Rated Load	8	12	60	100
Hertz/Cycles	60	60	60	60
Voltage PH1	208	208	208	208
PH2	208	208	208	208
PH3	208	208	208	208
Amperage PH1	55.5	83.3	416.3	693
PH2	55.5	83.3	416.3	693
PH3	55.5	83.3	416.3	693
Kilowatts	20	30	150	250
Oil Pressure	49	47	46	46
Coolant Temperature	175	176	180	192
DC Voltage	-	-	-	-
DC Amperage	-	-	-	-
Natural Gas Press	4.5	4.5	4.5	5
Engine Hours	192	-	-	-
Room Temp	-	-	-	-
Ambient Temp	-	-	-	-

FIELD NOTES

Test
Performed
@ 1.0
Power
Factor.

TEST DATE: 10-06-16 CEES
PAGE 1 of 1 TECHNICIAN(S): _____

LOAD BANK TESTING RESULTS