



Customer: C.S.D.G.
 Address: 2001 South Prairie Ave.
 City/ State/ Zip Waukesha
 Contact: Patrick Paden
 Phone:

R#: 5128
 Test Date 4/5/2018

Engine Make/ Model: Caterpillar, 3508
 Engine Spec/ Serial: 7C-4594
 Unit Make/ Model: Caterpillar, SR4
 Unit Spec/ Serial: 7C-1620, 5UA01422

Voltage: 480
 Amperage: 962
 Kilowatts: 800
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour
Eng Hours	969.5	970.5
Hertz/Cycles	60.1	60.1	60.1	60.1	60.1
Voltage PH1	480	480	480	480	480
PH2	481	481	481	481	481
PH3	480	480	480	480	480
Amperage PH1	961	961	961	961	961
PH2	962	962	962	962	962
PH3	961	961	961	961	961
Kilowatts	799	799	799	799	799
Oil Pressure	72	66	62	62	62
Oil Temperature	NA	NA
Coolant Temperature	176°F	180°F	183°F	183°F	183°F
Man Vac./Press. L/B	NA	NA
Man Vac./Press. R/B	NA	NA
L/B Exhaust Temp	NA	NA
R/B Exhaust Temp	NA	NA
Exhaust Temperature	NA	NA
DC Voltage	27.4	27.4	27.3	27.3	27.3
Natural Gas Pressure	NA	NA
Diesel Fuel Level	FULL	FULL	FULL	FULL	FULL
Room Temperature	NA	NA
Ambient Temperature	29°F	29°F	29°F	29°F	29°F

Cable Length: 25'

Cable/ Leg: 3

Connection Point: Bus Bar

Technician Signature: J. Merlo

P. Paden