

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make & Model: Cummins DFEK-1333102

Engine Make & Model: Cummins QSX15-G9

Serial No.: G130528620

Serial No.: 79672830

Rating: kW 500 Volts 277/480 Amps 601 Hertz 60 P.F. 1.0

Test Date: <u>10/31/16</u>	10 min	10 min	10 min	10 min	10 min	10 min	10 min	10 min
% Rated Load	0	100	100	100	100	100	100	0
Hertz/Cycles	60	60	60	60	60	60	60	60
Voltage PH1	480	481	480	480	480	480	481	480
PH2	481	481	480	481	481	481	480	481
PH3	480	480	480	481	480	480	481	480
Amperage PH1	0	601	601	600	601	601	601	0
PH2	0	600	601	601	600	600	600	0
PH3	0	600	600	601	600	600	601	0
Kilowatts	0	500	500	500	500	500	500	0
Oil Pressure	44	41	41	41	41	41	41	42
Coolant Temperature	WARMUP	183	183	183	183	183	183	COOLDOWN
DC Voltage	27.2	27.2	27.2	27.2	27.2	27.2	27.2	27.2
DC Amperage	0	0	0	0	0	0	0	0
Natural Gas Press	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Diesel Fuel Level	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Room Temp	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Ambient Temp	60	60	60	60	60	60	60	60

FIELD NOTES

Exhaust Flex Cracked
 Test Performed @ 1.0 Power Factor.

TEST DATE: 10-31-16

CEES TECHNICIAN(S): Randy P.

PAGE 1 of 1

LOAD BANK TESTING RESULTS