

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make & Model: Caterpillar D80-4

Engine Make & Model: Caterpillar C4.4

Serial No. N4E01135

Serial No.: E4M04253

Rating: kW 80 Volts 277/480 Amps 96 Hertz 60 P.F. 1.0

Run Time	10 min	10 min	10 min	10 min	10 min	10 min	10 min	10 min
% Rated Load	0	100	100	100	100	100	100	0
Hertz/Cycles	60	60	60	60	60	60	60	60
Voltage PH1	480	479	480	481	480	480	481	480
PH2	481	481	481	479	481	481	479	481
PH3	480	480	480	480	481	480	481	480
Amperage PH1	0	96	96	96	96	96	96	0
PH2	0	96	96	96	96	96	96	0
PH3	0	96	96	96	96	96	96	0
Kilowatts	0	80	80	80	80	80	80	0
Oil Pressure	57	55	53	53	52	52	52	54
Coolant Temperature	WARMUP	175	176	176	176	177	177	COOLDOWN
DC Voltage	13.7	13.7	13.7	13.7	13.7	13.7	13.7	13.7
Natural Gas Press	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Diesel Fuel Level	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Ambient Temp	43	43	44	44	44	44	45	45

FIELD NOTES

TEST DATE: 11/14/16

CEES

TECHNICIAN(S):

Randy P.

PAGE 1 of 1

LOAD BANK TESTING RESULTS