

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make & Model: Kohler 150ROZJ81

Engine Make & Model: John Deere 6076A

Serial No.: 354363

Serial No.: RG6076A199156

Rating: kW 150 Volts 120/208 Amps 417 Hertz 60 P.F. 1.0

Test Date:	10 min	10 min	10 min	10 min	10 min	10 min	10 min	10 min
% Rated Load	0	100	100	100	100	100	100	0
Hertz/Cycles	61.2	58.2	58.2	58.2	58.2	58.2	58.2	61.2
Voltage PH1	208	207	208	208	207	208	208	208
PH2	207	208	207	207	208	207	207	207
PH3	208	209	208	207	208	208	209	208
Amperage PH1	0	417	416	417	418	416	417	0
PH2	0	416	417	417	417	417	418	0
PH3	0	418	417	416	416	415	416	0
Kilowatts	0	150	150	150	150	150	150	0
Oil Pressure	38	35	35	35	35	35	35	37
Coolant Temperature	WARMUP	190	190	190	190	190	190	COOLDOWN
DC Voltage	14.4	14.4	14.4	14.4	14.4	14.4	14.4	14.4
Natural Gas Press	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Diesel Fuel Level	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Ambient Temp	52	52	52	53	53	53	53	53

FIELD NOTES	Circuit Breaker Lug Phase A stripped.	Engine Block Heater Defective. 120V 1500W.	Cowl Muffler rusted through at outlet.
-------------	---------------------------------------	--	--

TEST DATE:	<u>11/14/16</u>	CEES TECHNICIAN(S):	<u>Randy P.</u>
PAGE	<u>1 of 1</u>		