

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make & Model: Elliot Power Systems 40RD
Serial No.: BW02J658

Engine Make & Model: ISUZU 4BG1
Serial No.: 430NA-2 WSZXL04 3DNA

Rating: kW 40 Volts 120/208 Amps 111 Hertz 60 P.F. 1.0

Test Date: <u>12/6/16</u>	10 min	10 min	10 min	10 min	10 min	10 min	10 min	10 min
% Rated Load	0	100	100	100	100	100	100	0
Hertz/Cycles	60	57.5	57.5	57.5	57.5	57.5	57.5	60
Voltage PH1	212	211	212	211	212	211	212	212
PH2	210	210	210	210	211	210	211	210
PH3	210	210	210	210	210	211	210	210
Amperage PH1	0	111	110	111	110	111	110	0
PH2	0	110	111	110	111	110	111	0
PH3	0	110	110	111	111	111	112	0
Kilowatts	0	40	40	40	40	40	40	0
Oil Pressure	50	49	48	48	47	47	47	49
Coolant Temperature	Warm-up	175	176	176	176	176	176	Cooldown
DC Voltage	14.4	14.4	14.4	14.4	14.4	14.4	14.4	14.4
DC Amperage	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Natural Gas Press	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Engine Hours	164	164.1	164.3	164.4	164.6	164.7	164.9	165
Room Temp	60	60	60	60	60	60	60	60
Ambient Temp	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a

Unit has 70 amp circuit breaker.

FIELD NOTES

TEST DATE: 12/6/16

PAGE 1 of 1

CEES
TECHNICIAN(S):

Randy P.