

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make & Model: Caterpillar

Engine Make & Model: Caterpillar

Serial No.: 8RM00583

Rating: kW 1360 Volts 277/480 Amps 1636 Hertz 60 P.F. 1.0

Test Date:	10 min	10 min	10 min	10 min	10 min	10 min	10 min	10 min
% Rated Load	0	1360	1360	1360	1360	1360	1360	0
Hertz/Cycles	60	60	60	60	60	60	60	60
Voltage PH1	480	480	479	480	479	480	481	480
PH2	480	481	480	481	479	481	480	480
PH3	481	479	480	480	480	481	481	481
Amperage PH1	0	1638	1638	1638	1637	1637	1639	0
PH2	0	1636	1638	1639	1638	1637	1637	0
PH3	0	1637	1637	1637	1640	1638	1638	0
Kilowatts	0	1360	1360	1360	1360	1360	1360	0
Oil Pressure	70	60	60	58	58	57	57	56
Coolant Temperature	WARMUP	185	185	186	186	186	186	COOLDOWN
DC Voltage	27.2	27.2	27.2	27.2	27.2	27.2	27.2	27.2
Natural Gas Press	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Diesel Fuel Level	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Ambient Temp	60	60	60	60	60	60	60	60

FIELD NOTES _____

TEST DATE: 1-10-17 CEES
 TECHNICIAN(S): Randy P.
 PAGE 1 of 1

LOAD BANK TESTING RESULTS