

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make & Model: Caterpillar 3508

Serial No.: 23Z05318

Rating: kW 750 Volts 277/480 Amps 902 Hertz 60 P.F. 1.0

| | | | | | | | | |
|---------------------|---------|--------|--------|--------|--------|--------|--------|----------|
| Run Time | 10 min | 10 min | 10 min | 10 min | 10 min | 10 min | 10 min | 10 min |
| % Rated Load | 0 | 100 | 100 | 100 | 100 | 100 | 100 | 0 |
| Hertz/Cycles | 60 | 60 | 60 | 60 | 60 | 60 | 60 | 60 |
| Voltage PH1 | 480 | 481 | 480 | 482 | 481 | 480 | 481 | 481 |
| PH2 | 482 | 481 | 481 | 481 | 480 | 482 | 480 | 480 |
| PH3 | 482 | 482 | 480 | 481 | 482 | 482 | 481 | 481 |
| Amperage PH1 | 0 | 902 | 901 | 902 | 900 | 902 | 901 | 0 |
| PH2 | 0 | 901 | 902 | 902 | 903 | 900 | 901 | 0 |
| PH3 | 0 | 902 | 902 | 903 | 902 | 903 | 902 | 0 |
| Kilowatts | 0 | 750 | 750 | 750 | 750 | 750 | 750 | 0 |
| Oil Pressure | 62 | 60 | 55 | 55 | 55 | 55 | 54 | 59 |
| Coolant Temperature | Warm-up | 175 | 175 | 175 | 175 | 175 | 175 | Cooldown |
| DC Voltage | 28 | 27 | 27 | 27 | 27 | 27 | 27 | 27 |
| DC Amperage | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a |
| Natural Gas Press | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a |
| Diesel Fuel Level | n/a | n/a | n/a | n/a | n/a | n/a | n/a | n/a |
| Ambient Temp | 40 | 41 | 41 | 41 | 41 | 41 | 41 | 41 |
| Hour Meter | 1511 | 1511 | 1511 | 1511 | 1511 | 1511 | 1511 | 1511 |

| | |
|-------------|--|
| FIELD NOTES | |
| | |

| | |
|---------------------------|--|
| TEST DATE: <u>2-15-17</u> | CEES TECHNICIAN(S): <u>Randy P.</u> |
| PAGE 1 of 1 | |

LOAD BANK TESTING RESULTS