

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make & Model: Olympian D100P2

Engine Make & Model: Perkins YB50604

Serial No.: E3792A/001

Serial No.:

Rating: kW 100 Volts 277/480 Amps 121 Hertz 60 P.F. 1.0

Test Date:	10 min	10 min	10 min	10 min	10 min	10 min	10 min	10 min
% Rated Load	0	100	100	100	100	100	100	0
Hertz/Cycles	60	60	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481	481	481
PH2	480	480	480	480	480	480	480	480
PH3	481	481	481	481	481	481	481	481
Amperage PH1	0	120	119	120	120	120	120	0
PH2	0	120	121	120	120	120	120	0
PH3	0	120	120	120	120	120	120	0
Kilowatts	0	100	100	100	100	100	100	0
Oil Pressure	50	45	45	45	44	44	44	45
Coolant Temperature	WARMUP	185	185	185	185	185	185	COOLDOWN
DC Voltage	13.7	13.7	13.7	13.7	13.7	13.7	13.7	13.7
Engine Hours	330.5	330.6	330.8	330.9	331.1	331.2	331.4	331.5
Natural Gas Press	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Diesel Fuel Level	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Ambient Temp	55	55	55	55	55	55	55	55

FIELD NOTES _____

TEST DATE: 1-31-17 CEES TECHNICIAN(S): Randy P.
 PAGE 1 of 1

LOAD BANK TESTING RESULTS