

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make & Model: Olympian D100P4 (5436)

Serial No.: OLY00000PD4P00P4

Rating: kW 100 Volts 120/208 Amps 277 Hertz 60 P.F. 1.0

Test Date:	10 min	10 min	10 min	10 min	10 min	10 min	10 min	10 min
% Rated Load	0	100	100	100	100	100	100	0
Hertz/Cycles	60	60	60	60	60	60	60	60
Voltage PH1	208	207	208	208	208	209	207	208
PH2	207	208	208	209	208	208	207	207
PH3	208	208	208	209	209	208	207	208
Amperage PH1	0	277	278	277	278	278	277	0
PH2	0	278	277	276	278	278	277	0
PH3	0	277	278	278	277	276	277	0
Kilowatts	0	100	100	100	100	100	100	0
Oil Pressure	70	65	65	65	65	65	65	65
Coolant Temperature	WARMUP	180	180	180	180	180	180	COOLDOWN
DC Voltage	13.7	13.7	13.7	13.7	13.7	13.7	13.7	13.7
Engine Hours	171	171	172	172	172	172	172	172
Natural Gas Press	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Diesel Fuel Level	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Ambient Temp	70	70	70	70	71	71	71	71

FIELD NOTES _____

TEST DATE: 2-22-17 CEES TECHNICIAN(S): Randy P.
 PAGE 1 of 1

LOAD BANK TESTING RESULTS