

CHARLES EQUIPMENT ENERGY SYSTEMS

LOAD BANK TESTING

Customer: Central States Diesel Generators
Address: 2001 S. Prairie Ave.
City/ State/ Zip: Waukesha, WI 53189
Contact: Patrick Paden
Phone: 262.955.7655

R#: 3118
Test Date: 2017.02.17

Engine Make/ Model: Detroit Diesel 6063TKG5
Engine Spec/ Serial: 06R0670843
Unit Make/ Model: Kohler 275RZD
Unit Spec/ Serial: S/N: 0727647 Spec: GM16899-GA1

Voltage: 480
Amperage: 421
Kilowatts: 280
Power Factor: 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	4.1	4.3	4.5	4.8	5.0	5.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	334	334	334	334	334	0
PH2	334	334	334	334	334	0
PH3	334	334	334	334	334	0
Kilowatts	277	277	277	277	277	0
Oil Pressure	73	70	53	50	50	68
Oil Temperature	N/A	N/A	N/A	N/A	N/A	N/A
Coolant Temperature	165°F	185°F	195°F	195°F	195°F	179°F
Man Vac./Press. L/B	N/A	N/A	N/A	N/A	N/A	N/A
Man Vac./Press. R/B	N/A	N/A	N/A	N/A	N/A	N/A
L/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A	N/A
R/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A	N/A
Exhaust Temperature	N/A	N/A	N/A	N/A	N/A	N/A
DC Voltage	27.6	27.6	27.6	27.6	27.6	27.6
Natural Gas Pressure	11"	11"	11"	11"	11"	11"
Diesel Fuel Level	N/A	N/A	N/A	N/A	N/A	N/A
Room Temperature	N/A	N/A	N/A	N/A	N/A	N/A
Ambient Temperature	42°F	42°F	42°F	42°F	42°F	42°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: Resale _____