

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make & Model: 500ROZD4

Serial No.: 0701723

Rating: kW 510 Volts 120/208 Amps 1416 Hertz 60 P.F. 1.0

Run Time	10 min	10 min	10 min	10 min	10 min	10 min	10 min	10 min
% Rated Load	0	100	100	100	100	100	100	0
Hertz/Cycles	60	60	60	60	60	60	60	60
Voltage PH1	209	208	209	209	208	208	209	209
PH2	208	208	209	209	208	209	208	208
PH3	205	204	204	204	205	205	204	205
Amperage PH1	0	1416	1418	1417	1416	1416	1417	0
PH2	0	1417	1416	1416	1417	1417	1416	0
PH3	0	1418	1419	1418	1418	1418	1417	0
Kilowatts	0	510	510	510	510	510	510	0
Oil Pressure	50	45	40	40	40	40	40	44
Coolant Temperature	Warm-up	170	175	175	175	175	175	Cooldown
DC Voltage	27.6	27.6	27.6	27.6	27.6	27.6	27.6	27.6
DC Amperage	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Natural Gas Press	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Diesel Fuel Level	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Ambient Temp	40	41	41	41	41	41	41	41
Hour Meter	633	633	633	633	633	633	633	633

FIELD NOTES

TEST DATE: 2-15-17

PAGE 1 of 1

CEES

TECHNICIAN(S): Randy P.

LOAD BANK TESTING RESULTS