

# Load Bank Test Form

# Central States Diesel Generators Stock# 2068

Generator Set Make & Model: **Katolight D600FRX4**

Generator Set Serial Number: **WA504769**

Rated KW: **600**      Rated Voltage: **277/480**      3 Phase      60Hz

Technician: **Randy P.**      Test Date: **3-13-17**

TIME	LOAD %	KW	AMPS Phase A	AMPS Phase B	AMPS Phase C	VOLTS Phase A-B	VOLTS Phase A-C	VOLTS Phase B-C	HZ	Oil Press.	Water Temp.	Ambient Temp.
2:40P	0	0	0	0	0	494	494	494	60	70	WARM UP	60
2:45P	100	600	701	702	701	494	493	494	60	70	165	60
2:55P	100	600	701	701	701	494	494	494	60	70	165	60
3:05P	100	600	700	701	701	494	494	494	60	70	165	60
3:15P	100	600	701	701	702	494	493	494	60	70	165	60
3:25P	100	600	701	702	701	494	494	493	60	70	165	60
3:35P	100	600	701	701	700	493	494	493	60	70	165	60
3:45P	100	600	701	700	702	494	493	494	60	70	165	60
3:50P	0	0	0	0	0	494	494	494	60	70	COOL DOWN	60

Comments \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_