

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make & Model: KOHLER 400REOZD (5386)
 Serial No.: 0708977

Rating: kW 405 Volts 277/480 Amps 487 Hertz 60 P.F. 1.0

Run Time	10 min	10 min	10 min	10 min	10 min	10 min	10 min	10 min
% Rated Load	0	100	100	100	100	100	100	0
Hertz/Cycles	60	60	60	60	60	60	60	60
Voltage PH1	481	482	481	481	482	481	482	481
PH2	480	481	481	480	481	481	481	481
PH3	480	481	480	480	481	480	480	481
Amperage PH1	0	485	484	485	485	483	483	0
PH2	0	476	477	476	477	477	476	0
PH3	0	477	477	476	477	478	477	0
Kilowatts	0	405	405	405	405	405	405	0
Oil Pressure	72	70	70	70	70	70	70	70
Coolant Temperature	Warm-up	180	180	180	180	180	180	Cooldown
DC Voltage	27.7	27.7	27.7	27.7	27.7	27.7	27.7	27.7
Natural Gas Press	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Ambient Temp	34	34	34	34	34	34	34	34
Hour Meter	429	429	429	429	429	429	429	430

FIELD NOTES	_____

TEST DATE: <u>2-24-17</u>	CEES TECHNICIAN(S): <u>Randy P.</u>
PAGE <u>1 of 1</u>	

LOAD BANK TESTING RESULTS