

Load Bank Test Form

Central States Diesel Generators Stock# 2078

Generator Set Make & Model: Kohler D20-01A

Generator Set Serial Number: 0397-08

Rated KW: 20

Rated Voltage: 120/208

Phase: 3

Hz: 60

Technician: Randy P.

Test Date: 3-13-17

TIME	LOAD %	KW	AMPS Phase A	AMPS Phase B	AMPS Phase C	VOLTS Phase A-B	VOLTS Phase A-C	VOLTS Phase B-C	HZ	Oil Press.	Water Temp.	Ambient Temp.
3:55P	0	0	0	0	0	206	207	206	60	58	WARM UP	50
4:00P	100	20	56	56	56	206	206	206	60	58	165	50
4:10P	100	20	56	55	56	206	206	206	60	58	165	50
4:20P	100	20	56	56	55	207	206	206	60	58	165	50
4:30P	100	20	56	55	56	207	207	207	60	58	165	50
4:40P	100	20	56	55	56	206	207	207	60	57	165	50
4:50P	100	20	56	56	56	207	206	207	60	57	165	50
5:00P	100	20	55	56	56	207	206	206	60	57	165	50
5:05P	0	0	0	0	0	206	207	206	60	58	COOL DOWN	50

Comments
