

Load Bank Test Form

Central States Diesel Generators Stock# 2080

Generator Set Make & Model: Kohler 180ROZJ

Generator Set Serial Number: 396321

Rated KW: 180

Rated Voltage: 277/480

Phase: 3

Hz: 60

Technician: Randy P.

Test Date: 3-13-17

TIME	LOAD %	KW	AMPS Phase A	AMPS Phase B	AMPS Phase C	VOLTS Phase A-B	VOLTS Phase A-C	VOLTS Phase B-C	HZ	Oil Press.	Water Temp.	Ambient Temp.
5:20P	0	0	0	0	0	482	481	482	60	50	WARM UP	60
5:25P	100	180	216	216	217	482	480	481	60	42	200	60
5:35P	100	180	216	217	216	482	481	482	60	40	200	60
5:45P	100	180	216	216	217	482	480	481	60	40	200	60
5:55P	100	180	216	217	216	482	480	481	60	40	200	60
6:05P	100	180	216	216	217	482	480	482	60	40	200	60
6:15P	100	180	217	216	216	481	481	481	60	40	200	60
6:25P	100	180	216	217	217	481	480	481	60	40	200	60
6:30P	0	0	0	0	0	482	481	482	60	40	COOL DOWN	60

Comments _____
