

Load Bank Test Form

Central States Diesel Generators Stock# 2082

Generator Set Make & Model: Kohler ONAN/CUMMINS DFLB-3370117

Generator Set Serial Number: D990897897

Rated KW: 1100 Rated Voltage: 277/480 Phase: 3 Hz: 60

Technician: Randy P. Test Date: 3-14-17

TIME	LOAD %	KW	AMPS Phase A	AMPS Phase B	AMPS Phase C	VOLTS Phase A-B	VOLTS Phase A-C	VOLTS Phase B-C	HZ	Oil Press.	Water Temp.	Ambient Temp.
2:53P	0	0	0	0	0	480	480	480	60	85	WARM UP	45
2:58P	100	1100	1332	1328	1331	480	479	480	60	78	182	45
3:08P	100	1100	1331	1326	1330	480	479	480	60	78	182	45
3:18P	100	1100	1328	1330	1331	480	479	480	60	78	182	45
3:28P	100	1100	1330	1328	1330	480	479	480	60	78	182	45
3:38P	100	1100	1328	1331	1328	480	479	480	60	78	182	45
3:48P	100	1100	1328	1323	1321	480	479	480	60	76	185	48
3:58P	100	1100	1330	1326	1322	480	479	480	60	76	185	49
4:03P	0	0	0	0	0	480	480	480	60	82	COOL DOWN	49

Comments _____

