

Load Bank Test Form

Central States Diesel Generators STOCK# 2085

Engine Make & Model: Caterpillar 30546

Engine Serial Number: *E4M4M03024* Arrangement: 291-0359

Generator Set Make & Model: Caterpillar D80-4

Generator Set Serial Number: CAT00C44HN4E00389

KW Rating: 80 Voltage: 277/480 Hz: 60 1.0 P.F. Test Amps: 97

Technician: Randy P. Test Date: 4-7-17 CEES W.O.# 3506 CEES Asset I.D. # CA-E4M4M03024

TIME	ENG Hours	KW	AMPS Phase A	AMPS Phase B	AMPS Phase C	VOLTS Phase A-B	VOLTS Phase A-C	VOLTS Phase B-C	HZ	Oil Press.	Water Temp.	Ambient Temp.
10:40A	19.2	0	0	0	0	481	480	480	60	58	WARM UP	45
10:45A	19.3	80	96	97	97	480	481	480	60	57	160	45
10:55A	19.5	80	97	96	96	480	480	480	60	56	160	45
11:05A	19.6	80	97	97	96	481	480	480	60	55	160	45
11:15A	19.8	80	96	97	97	480	481	480	60	55	160	45
11:25A	19.9	80	97	96	97	481	480	481	60	55	160	45
11:35A	20.1	80	96	96	97	480	480	481	60	55	160	45
11:45A	20.2	80	96	97	96	480	481	480	60	55	160	45
11:50A	20.3	0	0	0	0	481	480	480	60	56	COOL DOWN	45

Comments _____
