

# Load/Bank Test Form

# Central States Diesel Generators STOCK# 2088

Engine Make & Model: VOLVO PENTA TWD1643GE

Engine Serial Number: 2016072854 869523

Generator Set Make & Model: NO TAG

Generator Set Serial Number: NO TAG

KW Rating: 600 Voltage: 277/480 Hz: 60 1.0 P.F. Test Amps: 722

Technician: Randy P. Test Date: 4-7-17 CEES W.O.# 3507 CEES Asset I.D. # VO-2016072854

TIME	ENG Hours	KW	AMPS Phase A	AMPS Phase B	AMPS Phase C	VOLTS Phase A-B	VOLTS Phase A-C	VOLTS Phase B-C	HZ	Oil Press.	Water Temp.	Ambient Temp.
1:40P	4744.6	0	0	0	0	479	481	481	60	80	WARM UP	45
1:45P	4744.7	600	722	721	724	480	480	481	60	80	175	45
1:55P	4744.9	600	724	722	721	481	481	480	60	73	177	45
2:05P	4745.0	600	721	724	722	480	480	481	60	69	177	46
2:15P	4745.2	600	722	722	724	481	480	480	60	69	179	46
2:25P	4745.3	600	721	720	723	480	481	481	60	69	179	46
2:35P	4745.5	600	723	721	723	481	481	480	60	69	179	46
2:45P	4745.6	600	722	723	721	480	481	481	60	69	179	46
2:50P	4745.7	0	0	0	0	479	481	481	60	72	COOL DOWN	46

Comments