

CHARLES EQUIPMENT ENERGY SYSTEMS

Customer: Central States Diesel Generators Stock # 2103
Address: 2001 S Prairie Ave.
City/ State/ Zip: Waukesha/ WI/ 53189
Contact: Patrick Paden
Phone: 847-997-8090

Engine Make/ Model: International / Perkins
Engine Spec/ Serial: WS4486N1. 467288
Unit Make/ Model: Olympian D200P4
Unit Spec/ Serial: OLY00000VNNS01364

Po

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours
Eng Hours	438.2	438.4	438.7	438.9	439.2		
Hertz/Cycles	60	60	60	60	60		
Voltage PH1	486	486	487	486	487		
PH2	487	487	486	486	486		
PH3	486	486	487	487	486		
Amperage PH1	0	238	239	237	238		
PH2	0	240	238	238	238		
PH3	0	239	237	238	239		
Kilowatts	0	200.10564	200	199.26486	200	0	0
Oil Pressure	60	55	55	55	55		
Oil Temperature							
Coolant Temperature	190°F	200°F	200°F	200°F	200°F		
Man Vac./Press. L/B							
Man Vac./Press. R/B							
L/B Exhaust Temp							
R/B Exhaust Temp							
Exhaust Temperature							
DC Voltage	27.8	27.8	27.8	27.8	27.8		
Natural Gas Pressure							
Diesel Fuel Level							
Room Temperature							
Ambient Temperature	65°F	65°F	66°F	66°F	67°F		

Cable Length: 8 feet

Cable/ Leg: 1 4/O per phase

Connec

Technician Signature: Randy P.

Customer

LOAD BANK TESTING

R#: 3711
Test Date 5/25/2017

Voltage: 277/480
Amperage: 241
Kilowatts: 200
Power Factor 1

2-1/2 Hr.	3 Hours	3-1/2 Hr.	4 Hours	Cool Down
				439.3
				60
				486
				487
				486
				0
				0
				0
0	0	0	0	0
				58
				190°F
				27.8
				67°F

Location Point: Circuit Breaker

Signature: _____