



Customer: Central States Diesel Generators STK#2110  
 Address: 2001 S Prairie Avenue  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 5341  
 Test Date 5/11/2018

Engine Make/ Model: Cummins QSB5-G7  
 Engine Spec/ Serial: 73661409  
 Unit Make/ Model: Doosan G70  
 Unit Spec/ Serial: CK3M17452

Voltage: Multiple  
 Amperage: Multiple  
 Kilowatts: 62  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1973.6	1973.8	1974.1	1974.3	1974.6	1974.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	480	479	480	480
PH2	481	481	481	481	481	481
PH3	480	480	481	481	481	480
Amperage PH1	0	74	75	75	74	0
PH2	0	75	74	74	75	0
PH3	0	75	75	75	75	0
Kilowatts	0	62	62	62	62	0
Oil Pressure	60	55	55	55	55	58
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.3	28.3	28.3	28.3	28.3	28.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	64°F	64°F	64°F	64°F	64°F	65°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_