

# CHARLES EQUIPMENT ENERGY SYSTEMS

**Customer:** Central States Diesel Generators CSDG STK#2124  
**Address:** 2001 S Prairie Ave (Door 26)  
**City/ State/ Zip:** Waukesha/ WI/ 53189  
**Contact:** Patrick Paden  
**Phone:** 262-955-7655

**Engine Make/ Model:** Perkins/International GCD325  
**Engine Spec/ Serial:** WS4486N1430548  
**Unit Make/ Model:** Cat/Olympian OLY00000CNNS00979  
**Unit Spec/ Serial:** 150466/02

Po

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	166.1	166.4	166.6	166.9	167.1	167.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	482	482	482	482	482	482
PH3	481	481	481	481	481	481
Amperage PH1	0	180	180	181	180	0
PH2	0	181	180	180	181	0
PH3	0	180	181	180	180	0
Kilowatts	0	150	150	150	150	0
Oil Pressure	45	42	40	40	40	42
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	60°F	61°F	61°F	61°F	61°F	61°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connec

Technician Signature: Randy P.

Customer