

CHARLES EQUIPMENT ENERGY SYSTEMS

Customer: Central States Diesel Generators STK#2126
Address: 2001 S Prairie Have.
City/ State/ Zip: Waukesha, WI 53189
Contact: Patrick Paden
Phone: 847-997-8090

Engine Make/ Model: Cummins KTA-38-G1
Engine Spec/ Serial: 33115827
Unit Make/ Model: Kohler 750ROZ71
Unit Spec/ Serial: 703132 A

Po

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1-1/2 Hr.	2 Hours
Eng Hours	348.7	348.9	349.2	349.4	349.7		
Hertz/Cycles	60	60	60	60	60		
Voltage PH1	482	482	482	482	482		
PH2	483	482	483	483	483		
PH3	482	483	482	482	482		
Amperage PH1	898	897	898	898	897		
PH2	895	898	897	897	898		
PH3	897	896	897	895	897		
Kilowatts	748.80628	747.97242	748.80628	748.80628	747.97242	0	0
Oil Pressure	75	72	70	70	70		
Oil Temperature							
Coolant Temperature	180°F	195°F	195°F	195°F	195°F		
Man Vac./Press. L/B							
Man Vac./Press. R/B							
L/B Exhaust Temp							
R/B Exhaust Temp							
Exhaust Temperature							
DC Voltage	28	28	28	28	28		
Natural Gas Pressure							
Diesel Fuel Level							
Room Temperature							
Ambient Temperature	81°F	81°F	82°F	82°F	82°F		

Cable Length: _____

Cable/ Leg: _____

Connec

Technician Signature: Randy P.

Customer

