



Customer: Central States Diesel Generators STK#2146
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5345
 Test Date 5/11/2018

Engine Make/ Model: Detroit Diesel 6063HK35
 Engine Spec/ Serial: Spec A 343692 06R0654371
 Unit Make/ Model: Kohler 400REOZD
 Unit Spec/ Serial: PA-705469. 0711222

Voltage: 277/480
 Amperage: 564
 Kilowatts: 375
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	493	493.2	493.5	493.7	494	494.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	480	480	480	480
PH2	480	480	480	480	481	481
PH3	480	480	481	481	480	480
Amperage PH1	0	451	450	451	451	0
PH2	0	450	450	450	450	0
PH3	0	451	451	450	450	0
Kilowatts	0	375	375	375	375	0
Oil Pressure	50	45	42	42	42	44
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.2	28.2	28.2	28.2	28.2	28.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	58°F	59°F	59°F	59°F	59°F	60°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____