

CHARLES EQUIPMENT ENERGY SYSTEMS

LOAD BANK TESTING

Customer: Central States Diesel Generators CSDG STK#2179
 Address: 2001 S Prairie Ave (Door 26)
 City/ State/ Zip Waukesha/ WI/ 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 4410
 Test Date 10/30/2017

Engine Make/ Model: John Deere 4045 HF285
 Engine Spec/ Serial: PE4045L188301
 Unit Make/ Model: Baldor TS130-3J
 Unit Spec/ Serial: 10.85130-G20 P1111070006

Voltage: 277/480
 Amperage: 121
 Kilowatts: 101
 Power Factor: 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1126.2	1126.4	1126.7	1126.9	1127.2	1127.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	469	469	469	468	469	469
PH2	469	469	469	469	469	469
PH3	467	468	467	467	467	467
Amperage PH1	0	124	124	124	124	0
PH2	0	123	124	123	123	0
PH3	0	124	123	124	123	0
Kilowatts	0	101	101	101	101	0
Oil Pressure	55	52	52	52	52	54
Oil Temperature						
Coolant Temperature	185°F	188°F	188°F	188°F	188°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.5	13.5	13.5	13.5	13.5	13.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	35°F	38°F	38°F	38°F	39°F	39°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy P.

Customer Signature: _____