

CHARLES EQUIPMENT ENERGY SYSTEMS

Customer: Central States Diesel Generators CSDG STK#2183
Address: 2001 S Prairie Ave (Door 26)
City/ State/ Zip: Waukesha/ WI/ 53189 10/23/2017
Contact: Patrick Paden
Phone: 262-955-7655

Engine Make/ Model: Cummins 6BTA5.9G3
Engine Spec/ Serial: 46359836
Unit Make/ Model: ONAN DGDK-5655894
Unit Spec/ Serial: L030584703 Spec B

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	290.1	290.3	290.6	290.8	291.1	291.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	207	207	207	207	207	207
PH3	208	208	208	208	208	208
Amperage PH1	0	348	348	347	348	0
PH2	0	349	347	348	347	0
PH3	0	348	348	348	348	0
Kilowatts	0	125	125	125	125	0
Oil Pressure	62	59	59	59	59	60
Oil Temperature						
Coolant Temperature	170°F	172°F	172°F	172°F	172°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	46°F	46°F	46°F	46°F	46°F	47°F

Cable Length: _____

Cable/ Leg: _____

Technician Signature: Randy P.