



Customer: CSDG STK#2185
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, Wisconsin 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: _____
 Test Date 4/23/2018

Engine Make/ Model: John Deere 6068HF475
 Engine Spec/ Serial: PE6068H514938
 Unit Make/ Model: Baldor T250T
 Unit Spec/ Serial: P0605170008

Voltage: 277/480 (Multi selectabl)
 Amperage: 241
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	2492	2492.2	2492.5	2492.7	2493	2493.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	479	480	480	480	480	479
PH2	480	479	479	479	479	480
PH3	479	479	479	480	479	479
Amperage PH1	0	240	241	241	241	0
PH2	0	241	240	240	240	0
PH3	0	241	242	240	241	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	47	44	43	43	43	45
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.7	13.7	13.7	13.7	13.7	13.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	59°F	59°F	60°F	60°F	60°F	60°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____