

CHARLES EQUIPMENT ENERGY SYSTEMS

Customer: Central States Diesel Generators CSDG STK#2187
Address: 2001 S Prairie Ave (Door 26)
City/ State/ Zip: Waukesha/ WI/ 53189 10/30/2017
Contact: Patrick Paden
Phone: 262-955-7655

Engine Make/ Model: Cummins N14G2
Engine Spec/ Serial: 11955336
Unit Make/ Model: ONAN DQBB-33375005
Unit Spec/ Serial: Spec D G990947191

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	48	48.2	48.5	48.7	49	49.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	481	481	481	481	481	481
PH3	481	480	481	480	480	481
Amperage PH1	0	421	420	421	421	0
PH2	0	420	421	420	420	0
PH3	0	421	420	421	421	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	55	52	52	52	52	54
Oil Temperature						
Coolant Temperature	185°F	188°F	188°F	188°F	188°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.2	27.2	27.2	27.2	27.2	27.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	35°F	38°F	38°F	38°F	39°F	39°F

Cable Length: _____

Cable/ Leg: _____

Technician Signature: Randy P.