

CHARLES EQUIPMENT ENERGY SYSTEMS

LOAD BANK TESTING

Customer: Central States Diesel Generators STK#2189
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 4520
 Test Date 11/20/2017

Engine Make/ Model: Cummins NTA-855-G3
 Engine Spec/ Serial: 30387368
 Unit Make/ Model: ONAN
 Unit Spec/ Serial:

Voltage: 277/480
 Amperage: 527
 Kilowatts: 350
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1414.8	1415	1415.3	1415.5	1415.8	1415.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	483	483	483	483
PH2	483	483	482	482	483	483
PH3	482	482	482	482	482	482
Amperage PH1	0	419	420	420	419	0
PH2	0	420	419	419	420	0
PH3	0	420	419	420	421	0
Kilowatts	0	350	351	351	350	0
Oil Pressure	60	55	55	55	55	55
Oil Temperature						
Coolant Temperature	175°F	185°F	185°F	185°F	185°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	38°F	38°F	38°F	39°F	39°F	39°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy P.

Customer Signature: _____