





Central California Generator, LLC  
7062 Prestwick Dr  
Riverbank, CA 95367

## Generator Load Bank Test Report

Job No: 2763  
Test Date: 12-19-17

Customer: Central State Diesel Generators Site: Isk  
 Address: 2005 Prairie Ave Site Address: 6900 Dumbarton Circle  
 City, State Zip: Waukegan WI 53185 City, State Zip: Fremont CA  
 Generator Make: Cummins Model: DFHD570194 Spec: E Serial No: 605080778  
 Engine Make: Cummins Model: QST30-G5 Engine Serial No: 37218036  
 kW Rating: 1000 Volts: 480 Hz: 60 Phase: 3 Wire: NA Hours: 34.8 - 35.8  
Patrick Padon Steady State Test

Time	Voltage			Amps			% Load	kW	Kilowatts, Cycles, Pressure		Temperature		Battery Charger		
	L1	L2	L3	L1	L2	L3			Hz	RPM	P.F.	Water		Ambient	
11:11	481	479	480	483	486	486	40	403	60	1800	1.0	66	151	56°	26.4
11:20	480	479	480	486	488	488	100	1003	60	1800	1.0	57	174	56°	26.2
11:30	481	479	480	482	486	486	100	1002	60	1800	1.0	54	178	56°	26.4
11:40	481	479	480	482	486	486	100	1003	60	1800	1.0	52	180	56°	26.4
11:50	481	479	480	485	488	488	100	1003	60	1800	1.0	52	181	57°	26.4
12:00	481	479	480	485	487	487	100	1003	60	1800	1.0	52	181	57°	26.4
12:10	481	479													

Customer: \_\_\_\_\_ Technician: B.D., DS Notes: No Problems To Report.

Office 209.863.0562 Fax 209.869.3927  
 Email: info@CCGpower.com  
 www.CCGpower.com