

# CHARLES EQUIPMENT ENERGY SYSTEMS

Customer: Central States Diesel Generators STK#2201  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

Engine Make/ Model: Detroit Diesel Series 60 6063HK35  
 Engine Spec/ Serial: 06R0569988  
 Unit Make/ Model: Kohler 400REOZD  
 Unit Spec/ Serial: 663991

Po

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	336	336.2	336.5	336.7	337	337.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	482	482	482	482	483
PH2	483	483	483	483	483	484
PH3	482	484	483	483	483	482
Amperage PH1	0	483	484	485	485	0
PH2	0	484	485	484	486	0
PH3	0	484	484	486	485	0
Kilowatts	0	403	404	404	404	0
Oil Pressure	40	38	35	35	35	38
Oil Temperature						
Coolant Temperature	180°F	188°F	188°F	188°F	188°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	35°F	35°F	35°F	36°F	36°F	36°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connec

Technician Signature: Randy P.

Customer