

CHARLES EQUIPMENT ENERGY SYSTEMS

LOAD BANK TESTING

Customer: Central States Diesel Generators CSDG STK#2205
 Address: 2001 S Prairie Ave (Door 26)
 City/ State/ Zip Waukesha/ WI/ 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 4756
 Test Date 1/24/2018

Engine Make/ Model: Cummins QSB7-G3 NR3
 Engine Spec/ Serial: 46721307
 Unit Make/ Model: Onan DSGAB-5960723
 Unit Spec/ Serial: E070062812

Voltage: 277/480
 Amperage: 188
 Kilowatts: 125
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	533	533.2	533.5	533.7	534	534.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	479	479	480	479	485	479
PH2	479	479	479	479	479	479
PH3	480	479	479	480	480	480
Amperage PH1	0	150	151	150	151	0
PH2	0	151	150	151	151	0
PH3	0	151	150	150	150	0
Kilowatts	0	125	125	125	125	0
Oil Pressure	58	55	55	55	55	56
Oil Temperature	N/A	N/A	N/A	N/A	N/A	N/A
Coolant Temperature	175°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B	N/A	N/A	N/A	N/A	N/A	N/A
Man Vac./Press. R/B	N/A	N/A	N/A	N/A	N/A	N/A
L/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A	N/A
R/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A	N/A
Exhaust Temperature	N/A	N/A	N/A	N/A	N/A	N/A
Natural Gas Pressure	13.9	13.9	13.9	13.9	13.9	13.9
Diesel Fuel Level	N/A	N/A	N/A	N/A	N/A	N/A
Room Temperature	N/A	N/A	N/A	N/A	N/A	N/A
Ambient Temperature	24°F	24°F	24°F	24°F	24°F	24°F

Cable Length: _____ Cable/ Leg: _____

Connection Point: _____

Technician Signature: **Randy P.**

Customer Signature: _____