

**Customer:** Central States Diesel Generators STK#2117  
**Address:** 2001 S Prairie Ave.  
**City/ State/ Zip:** Waukesha, WI 53189  
**Contact:** Patrick Paden  
**Phone:** 262-955-7655

**R#:** 5028  
**Test Date:** 3/19/2018

**Engine Make/ Model:** Cummins KTA50-G3  
**Engine Spec/ Serial:** 33145179  
**Unit Make/ Model:** ONAN DFLLC-4476270  
**Unit Spec/ Serial:** C000084249

**Voltage:** 277/480  
**Amperage:** 1504  
**Kilowatts:** 1250  
**Power Factor:** 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	366.5	366.7	367	367.2	367.5	367.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	480	480	481	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	1504	1502	1503	1505	0
PH2	0	1504	1503	1505	1505	0
PH3	0	1503	1503	1504	1503	0
Kilowatts	0	1250	1250	1250	1250	0
Oil Pressure	85	80	76	75	75	77
Oil Temperature						
Coolant Temperature	175°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.9	27.9	27.9	27.9	27.9	27.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	34°F	34°F	34°F	34°F	34°F	34°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: Randy P.

Customer Signature: \_\_\_\_\_