

Customer: Central States Diesel Generators STK#2227
 Address: 2001 S Rairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 4948
 Test Date 3/8/2018

Engine Make/ Model: MTU R0837K36
 Engine Spec/ Serial: 5312000821
 Unit Make/ Model: Kohler 500ROZD4
 Unit Spec/ Serial: 0671926

Voltage: 277/480
 Amperage: 606
 Kilowatts: 505
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	393.3	393.5	393.8	394	394.3	394.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	486	485	485	485	485	485
PH2	486	486	486	486	484	486
PH3	484	485	484	485	485	485
Amperage PH1	0	606	605	603	605	0
PH2	0	605	602	604	605	0
PH3	0	604	602	604	604	0
Kilowatts	0	508	506	507	507	0
Oil Pressure	75	65	65	65	65	70
Oil Temperature						
Coolant Temperature	170°F	175°F	175°F	175°F	175°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.2	28.2	28.2	28.2	28.2	28.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	25°F	25°F	25°F	25°F	25°F	25°F

Cable Length: _____ Cable/ Leg: _____ Connection Point: _____

Technician Signature: Randy P.

Customer Signature: _____