

CHARLES EQUIPMENT ENERGY SYSTEMS

LOAD BANK TESTING

Customer: Central States Diesel Generators CSDG STK#2228
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha/ WI/ 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 4928
 Test Date 3/2/2018

Engine Make/ Model: Cummins LTA-10G1
 Engine Spec/ Serial: 34858331
 Unit Make/ Model: Onan 250DFAC
 Unit Spec/ Serial: D970636931

Voltage: 277/480
 Amperage: 301
 Kilowatts: 250
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1048.1	1048.3	1048.6	1048.8	1049.1	1049.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	483	483	483	483
PH2	483	482	483	482	483	483
PH3	483	483	483	483	482	483
Amperage PH1	0	301	300	301	301	0
PH2	0	301	300	300	300	0
PH3	0	301	301	301	301	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	45	35	33	31	31	45
Oil Temperature						
Coolant Temperature	180°F	186°F	186°F	186°F	186°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	32°F	33°F	33°F	33°F	34°F	34°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy P.

Customer Signature: _____