


# Invoice

03/14/2018

## Charles Equipment

Charles Equipment Energy Systems  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

4928-1



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: U# 2227

### Notes

INSPECT UNIT, PERFORMED LOADBANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		03/14/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	2 hr	\$ 220.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 220.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 220.00


# Invoice

03/13/2018

## Charles Equipment

Charles Equipment Energy Systems  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

4939



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: U# 2232

### Notes

PERFORMED INSPECTION AND PERFORMED 1HR LOAD BANK TEST, RECALIBRATED AMPS AND LOAD PERCENT TO EQUAL ACTUAL VALUE

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		03/13/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	2.5 hr	\$ 275.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 275.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 275.00

**CHARLES EQUIPMENT ENERGY SYSTEMS**

**LOAD BANK TESTING**

Customer: Central States Diesel Generators CSDG STK#2232  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha/ WI/ 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 4939  
 Test Date 3/5/2018

Engine Make/ Model: LTA-10G3  
 Engine Spec/ Serial: 34879006  
 Unit Make/ Model: Onan 200DFAB  
 Unit Spec/ Serial: I970650368

Voltage: 120/208  
 Amperage: 555  
 Kilowatts: 200  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	70	70.2	70.5	70.7	71	71.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	208	209	208	208	208	208
PH3	209	209	209	209	209	209
Amperage PH1	0	555	555	556	555	0
PH2	0	554	554	554	553	0
PH3	0	553	555	555	554	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	41	33	33	33	33	39
Oil Temperature						
Coolant Temperature	180°F	186°F	187°F	187°F	187°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	32°F	32°F	32°F	32°F	32°F	33°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: Randy P.

Customer Signature: \_\_\_\_\_

# Work Order

<p>WO No: 4939          WO Date: 03/05/2018          Sched. Date: 03/05/2018          Completed Date: 03/05/2018          Bill With Work Order:          Follow Up From WO#: 0          Customer P.O. No.:          CEES Quote:</p>	<p>Open / History: 0          Job Status: Invoice          Status Change Date: 2018.03.05 (INV)          Assign To Type: Technician          Assign To: (RANDY POOL)</p>
<p>Site: CENTRAL STATES DIESEL GENERATORS          Site_addr: 2001 S. PRAIRIE AVE.          City: WAUKESHA          State: WISCONSIN          Zip: 53189          Requested By: PATRICK PADEN          Req. Telephone:          Req. E-mail:          Bill To: (Invoice): CENTRAL STATES DIESEL GENERATORS          Account #: 1121          Perform For Type: Customer          Perform For: CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)</p>	<p>Asset ID: CU-34879006          Unit #: 2232          Engine Make: CUMMINS          Engine Model No.: LTA10G3          Engine Serial No.: 34879006          Engine Spec:          Unit Make: CUMMINS/ ONAN          Unit Model No.: 200DFAB          Unit Serial No.: 1970650368          Unit Spec: 80989G          Engine Hours: 71.10</p>
	<p>Round Trip Miles: 0          Tolls Paid: 0</p>
	<p>Time In: 03/05/2018 02:03:00 PM          Time Out: 03/05/2018 02:03:00 PM</p>
<p>WO Type: Load Bank          Problem Type: INSPECT AND LOAD BANK FOR SALE          Brief Description: INSPECT AND LOAD BANK FOR SALE</p>	<p>Signed Signature:</p>
<p>Customer Complaint: PERFORM INSPECTION          PERFORM 1-HOUR LOAD-BANK TETST</p>	
<p>Work Performed: PERFORMED INSPECTION OF UNIT PRIOR TO TESTING. PERFORMED 1 HOUR LOAD BANK TEST. RECALIBRATED AMPS AND LOAD PERCENT TO EQUAL ACTUAL VALUE. COMPLETED TEST REPORT.</p>	
<p>Follow-Ups:</p>	


# Invoice

03/13/2018

## Charles Equipment

Charles Equipment Energy Systems  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

4940



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: U# 2233

### Notes

PERFORMED INSPECTION AND PERFORMED 1HR LOAD BANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		03/13/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	2 hr	\$ 220.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 220.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 220.00

**CHARLES EQUIPMENT ENERGY SYSTEMS**

**LOAD BANK TESTING**

Customer: Central States Diesel Generators CSDG STK#2233  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha/ WI/ 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 4940  
 Test Date 3/5/2018

Engine Make/ Model: LTA-10G3  
 Engine Spec/ Serial: 34879007  
 Unit Make/ Model: Onan 200DFAB  
 Unit Spec/ Serial: I970650369

Voltage: 120/208  
 Amperage: 555  
 Kilowatts: 200  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	188.9	189.1	189.4	189.6	189.9	190
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	209	209	209	209	209	209
PH2	209	209	209	209	209	208
PH3	210	209	210	210	210	210
Amperage PH1	0	554	554	556	554	0
PH2	0	553	554	554	553	0
PH3	0	553	556	555	553	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	41	34	34	34	34	40
Oil Temperature						
Coolant Temperature	180°F	187°F	188°F	188°F	188°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	33°F	33°F	33°F	34°F	34°F	34°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: Randy P.

Customer Signature: \_\_\_\_\_

# Work Order

WO No.: 4940 WO Date: 03/05/2018 Sched. Date: 03/05/2018 Completed Date: 03/05/2018 Bill With Work Order: Follow Up From WO#: 0 Customer P.O. No.: CEES Quote:		<input type="checkbox"/>		Open / History: 0 Job Status: Invoice Status Change Date: 2018.03.05 (INV) Assign To Type: Technician Assign To: (RANDY POOL)	
Site: CENTRAL STATES DIESEL GENERATORS Site_addr: 2001 S. PRAIRIE AVE. City: WAUKESHA State: WISCONSIN Zip: 53189 Requested By: PATRICK PADEN Req. Telephone: Req. E-mail: Bill To: (Invoice): CENTRAL STATES DIESEL GENERATORS Account #: 1121 Perform For Type: Customer Perform For: CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		Asset ID: CU-34879007 Unit #: 2233 Engine Make: CUMMINS Engine Model No.: LTA10G3 Engine Serial No.: 34879007 Engine Spec: Unit Make: CUMMINS/ ONAN Unit Model No.: 200DFAB Unit Serial No.: 1970650369 Unit Spec: 80989G Engine Hours: 190		Round Trip Miles: 0 Tolls Paid: 0	
WO Type: Load Bank Problem Type: INSPECT AND LOAD BANK FOR SALE Brief Description: INSPECT AND LOAD BANK FOR SALE Customer Complaint: PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST Work Performed: PERFORMED INSPECTION OF UNIT PRIOR TO LOAD BANK TEST. PERFORMED 1 HOUR LOAD BANK TEST. COMPLETED TEST REPORT.		Time In: 03/05/2018 02:07:00 PM Time Out: 03/05/2018 02:07:00 PM Signed Signature:			
Follow-Ups:					


# Invoice

03/13/2018

## Charles Equipment

Charles Equipment Energy Systems  
530 Santa Rosa Drive  
Des Plaines, IL 60018  
Phone: (630) 834-6000  
Fax: (630) 543-4174  
Email: cees@charlesequipment.com

4942



### Bill To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Customer: CENTRAL STATES DIESEL GENERATOR

### Ship To:

CENTRAL STATES DIESEL GENERATOR  
2001 S. PRAIRIE AVE  
WAUKESHA, WI 53189

Contact: CENTRAL STATES DIESEL GENERATO  
PO Number: UNIT# 2234

### Notes

PERFORMED INSPECTION OF UNIT AND PERFORMED 1HR LOAD BANK TEST

Seller	Payment Terms	FOB Point	Carrier	Ship Service	Requested Ship Date
debbs	Net 10	Origin	Will Call		03/05/2018

Item #	Type	Number / Description	Unit Price	Qty Ordered	Total Price
1	Sale	SFT/M/WI - STRAIGHT FIELD LABOR - WI	\$ 110.00	2 hr	\$ 220.00

This invoice is based on CEES standard conditions of sale, whether attached hereto or not, a copy of which is on file at the CEES corporate office. CEES hereby objects to any additional or different terms set forth in any request for quotation, specification, purchase order or any other document of purchaser or provided by purchaser. Acceptance of additional or different terms must be specifically agreed to in writing by CEES. All credit card payments will be charged a 3% administration fee.

**Subtotal:** \$ 220.00  
**Sales Tax:** \$ 0.00  
**Total:** \$ 220.00



**CHARLES EQUIPMENT ENERGY SYSTEMS**

**LOAD BANK TESTING**

Customer: Central States Diesel Generators CSDG STK#2234  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha/ WI/ 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 4942  
 Test Date 3/5/2018

Engine Make/ Model: QSM11G2  
 Engine Spec/ Serial: 35084637  
 Unit Make/ Model: Onan DQAF-5630694  
 Unit Spec/ Serial: I030547102

Voltage: 277/480&120/208&139/240  
 Amperage: 361@277/480V  
 Kilowatts: 300  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	138.8	139	139.3	139.5	139.8	139.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	484	484	485	484	484	484
PH2	485	484	484	484	485	485
PH3	485	485	485	485	485	485
Amperage PH1	0	360	361	361	360	0
PH2	0	361	360	360	361	0
PH3	0	361	359	360	361	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	45	33	33	33	33	39
Oil Temperature						
Coolant Temperature	170°F	185°F	185°F	185°F	185°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.2	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	30°F	30°F	30°F	30°F	30°F	30°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: Randy P.

Customer Signature: \_\_\_\_\_

# Work Order

WO No: 4942 WO Date: 03/05/2018 Sched. Date: 03/05/2018 Completed Date: 03/05/2018 Bill With Work Order: Follow Up From WO#: 0 Customer P.O. No.: CEES Quote:		<input checked="" type="checkbox"/>	Open / History: 0 Job Status: Invoice Status Change Date: 2018.03.05 (INV) Assign To Type: Technician Assign To: (RANDY POOL)
Site: CENTRAL STATES DIESEL GENERATOR Site_addr: 2001 S. PRAIRIE AVE. City: WAUKESHA State: WISCONSIN Zip: 53189 Requested By: PATRICK PADEN Req. Telephone: Req. E-mail: Bill To: (Invoice): CENTRAL STATES DIESEL GENERATORS Account #: 1121 Perform For Type: Customer Perform For: CENTRAL STATES DIESEL GENERATORS (CENTRAL STATES DIESEL GENERATORS)		Asset ID: CU-35084637 Unit #: 2234 Engine Make: CUMMINS Engine Model No: QSM11G2 Engine Serial No: 35084637 Engine Spec: Unit Make: ONAN Unit Model No: DQAF-5630694 Unit Serial No: 1030547102 Unit Spec: B Engine Hours: 139.90	
Round Trip Miles: 0 Tolls Paid: 0		Time In: 03/05/2018 04:55:00 PM Time Out: 03/05/2018 04:55:00 PM	
WO Type: Load Bank Problem Type: INSPECT AND LOAD BANK FOR SALE Brief Description: INSPECT AND LOAD BANK FOR SALE		Signed Signature:	
Customer Complaint: PERFORM INSPECTION PERFORM 1-HOUR LOAD-BANK TEST			
Work Performed: PERFORMED INSPECTION OF UNIT PRIOR TO LOAN A TEST. PERFORMED 1 HOUR LOAD BANK TEST. COMPLETED TEST REPORT.			
Follow-Ups:			