

CHARLES EQUIPMENT ENERGY SYSTEMS

LOAD BANK TESTING

Customer: Central States Diesel Generators CSDG STK#2234
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha/ WI/ 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 4942
 Test Date 3/5/2018

Engine Make/ Model: QSM11G2
 Engine Spec/ Serial: 35084637
 Unit Make/ Model: Onan DQAF-5630694
 Unit Spec/ Serial: 1030547102

Voltage: 277/480&120/208&139/240
 Amperage: 361@277/480V
 Kilowatts: 300
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	138.8	139	139.3	139.5	139.8	139.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	484	484	485	484	484	484
PH2	485	484	484	484	485	485
PH3	485	485	485	485	485	485
Amperage PH1	0	360	361	361	360	0
PH2	0	361	360	360	361	0
PH3	0	361	359	360	361	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	45	33	33	33	33	39
Oil Temperature						
Coolant Temperature	170°F	185°F	185°F	185°F	185°F	178°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.2	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	30°F	30°F	30°F	30°F	30°F	30°F

Cable Length: _____ Cable/ Leg: _____ Connection Point: _____

Technician Signature: Randy P. Customer Signature: _____