



Customer: Central States Diesel Generators STK#2236  
 Address: 2001 S Rairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 4972  
 Test Date 3/8/2018

Engine Make/ Model: TE618705 6E02  
 Engine Spec/ Serial: 87800867  
 Unit Make/ Model: Generac 97A00543-S  
 Unit Spec/ Serial: 2032859

Voltage: 277/480  
 Amperage: 225  
 Kilowatts: 150  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	342.3	342.5	342.8	343	343.3	343.4
Hertz/Cycles	61	59	59	59	59	61
Voltage PH1	485	485	485	485	485	485
PH2	486	486	486	486	486	486
PH3	485	485	485	485	485	485
Amperage PH1	0	179	180	179	180	0
PH2	0	179	178	179	178	0
PH3	0	179	179	179	179	0
Kilowatts	0	150	150	150	150	0
Oil Pressure	55	50	50	50	50	50
Oil Temperature						
Coolant Temperature	180°F	195°F	195°F	195°F	195°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.5	14.5	14.5	14.5	14.5	14.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	24°F	24°F	24°F	25°F	25°F	25°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: Randy P.

Customer Signature: \_\_\_\_\_