

Customer: Central States Diesel Generators STK#2238
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 4992
 Test Date 3/13/2018

Engine Make/ Model: Cummins NTA855G5
 Engine Spec/ Serial: 11836520
 Unit Make/ Model: ONAN 400DFCE
 Unit Spec/ Serial: B970631061

Voltage: 277/480
 Amperage: 481
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	311.1	311.3	311.6	311.8	312	312.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	484	483	483	483	485
PH2	484	483	484	484	483	486
PH3	484	484	484	483	484	485
Amperage PH1	0	480	480	481	480	0
PH2	0	481	480	480	480	0
PH3	0	481	481	480	481	0
Kilowatts	0	402	402	402	402	0
Oil Pressure	60	50	48	46	46	49
Oil Temperature						
Coolant Temperature	175°F	181°F	181°F	181°F	181°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	27°F	27°F	27°F	27°F	27°F	27°F

Cable Length: _____ Cable/ Leg: _____ Connection Point: _____

Technician Signature: Randy P.

Customer Signature: _____