

Customer: CSDG STK#2239
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, Wisconsin 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5036
 Test Date 3/21/2018

Engine Make/ Model: John Deere 6081AF001
 Engine Spec/ Serial: RG6081A098629
 Unit Make/ Model: Kohler 150ROZJ
 Unit Spec/ Serial: 0655624 spec. PA-189852

Voltage: 277/480
 Amperage: 193
 Kilowatts: 160
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	505.3	505.5	505.8	506	506.3	506.4
Hertz/Cycles	62.4	60	60	60	60	62.4
Voltage PH1	483	483	482	483	483	483
PH2	482	482	483	483	482	482
PH3	482	483	483	482	483	482
Amperage PH1	0	192	192	192	191	0
PH2	0	193	191	191	192	0
PH3	0	192	191	192	191	0
Kilowatts	0	161	160	160	160	0
Oil Pressure	44	40	40	40	40	42
Oil Temperature						
Coolant Temperature	175°F	180°F	180°F	180°F	180°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	15.1	15.1	15.1	15.1	15.1	15.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	28°F	28°F	28°F	29°F	29°F	29°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____