

Unit

Serial Number	In-Service Date	Warranty Expiration	Sales Order Number
3029056	01/11/2012	01/11/2014	1009841325
Parts Coverage	Labor Coverage	Travel Coverage	
24 Months / 2000 Hours	24 Months / 2000 Hours	24 Months / 2000 Hours	
Model	Specification Number	Product ID	Material
250REOZJE	GM66100-GA5	Generator Set	250REOZJE
Test Date	Engine Serial Number	Engine Manufacturer Name	Engine Model
12/03/2011	RG6090L110142	JOHN DEERE	6090HF484
Engine RPM	Fuel Type	KW	KVA
1800	Diesel	255	319.00
Amps	Power Factor	Hertz	Phase
383.00	0.80	60	3
Low Volt	High Volt	Battery Volt	Market
277	480	24	Industrial
Brand	Usage	Standard Warranty Desc.	Extended Warranty Desc.
Kohler Generator Brand	Standby	1 Year Industrial Standby Standard Warranty	2 Year Industrial Basic Extended Warranty
Standard Warranty Part #	Extended Warranty Part #		
GM50088	221665		

Kits

Kit Type	Kit Material Number	Kit Description
Installed	GM76120-KA1	Block Heater, 2500W, 90/120V, 1Ph
Installed	GM19874-KA1	Decal, UL2200 Listing (Diesel)
Installed	GM75793-KA1	Air Cleaner Restriction Ind.
Installed	GM69552-KA1	Inner Tank Leak Alarm
Installed	324588	Battery,2/12V,950CCA,Wet
Installed	GM69406-MA1	Skid/Tank Module, 230-275 JD
Installed	GM28625-KA5	Coolant in Genset 9 gals.
Installed	GM50890-KA3	Neutral, 1313A. 4UA
Installed	GM51860-KA3	Covers, 4UA J-Box, L-Frame LCB
Installed	222661	Nameplate Rating, Standby 130 Degree
Installed	GM69553-MA1	Unit Mounted Radiator Cooling
Installed	GM75749-KA10	Run Relay, 24V
Installed	GM75604-MA1	Standard Duty Air Intake
Installed	GM58642-MA31	Alternator, 4UA13
Installed	333708	Voltage,60Hz,277/480V,3Ph,4W,0.8PF
Installed	GM75749-KA5	Accessory Inner Panel
Installed	GM52296-KA1	LCB, 400A, LAP, Therm Mag, 80%
Installed	GM75592-KA1	Enclosure, Steel Sound
Installed	GM70131-MA1	Control & Harness, DEC3000
Installed	GM71450-AA1	Software, Fuel Level & Fuel in Basin
Installed	GM28569-KA4	Charger, Battery Float/Equalize 24V
Installed	GM50882-KA1	MTG, LCB, L-Frame 300-400A, 4UA
Installed	GM77896-KA3	Rodent Guards, Non CSA, 4UA
Installed	GM39513-KA2	Flexible Fuel Lines
Installed	GM75749-KA6	DEC3000 2Input/5Output
Installed	GM70133-MA1	Controller & Mtg, DEC3000,1200A,STD,3PH

Unit Registrations