



Customer: Central States Diesel Generators
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone:

R#: 4997
 Test Date 3/16/2017

Engine Make/ Model: FORD WSG1068IT-6005-A
 Engine Spec/ Serial: 3833963
 Unit Make/ Model: ONAN GGGHG-5552338
 Unit Spec/ Serial: A B020337599

Voltage: 240
 Amperage: 243
 Kilowatts: 85
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1106.7	1107	1107.2	1107.5	1107.7	1107.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	240	242	240	242	242	242
PH2	240	241	242	241	241	241
PH3	241	241	241	241	241	241
Amperage PH1	108	108	108	205	205	0
PH2	107	107	107	205	204	0
PH3	108	107	108	204	205	0
Kilowatts	45	45	45	85	85	0
Oil Pressure	85	80	75	70	70	75
Oil Temperature						
Coolant Temperature	125°F	200°F	200°F	200°F	200°F	195°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.08	14.09	14.09	14.09	14.09	14.09
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	32°F	32°F	32°F	32°F	32°F	32°F

Cable Length: 25

Cable/ Leg: 1

Connection Point: BREAKER

Technician Signature: Rudy Aceves

Customer Signature: