



Customer: Central States Diesel Generators STK#2245
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5385
 Test Date 5/14/2018

Engine Make/ Model: John Deere 6068HF 150
 Engine Spec/ Serial: CD6068H643638
 Unit Make/ Model: SDMO JS170UC
 Unit Spec/ Serial: JS170IV-US/4732400-001

Voltage: 120/208
 Amperage: 472
 Kilowatts: 170
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	50:20:00	50:35:00	50:50:00	51:05:00	51:20:00	51:25:00
Hertz/Cycles	61.6	59.3	59.3	59.3	59.3	61.6
Voltage PH1	218	219	219	219	219	218
PH2	218	219	219	219	219	218
PH3	219	219	219	219	219	219
Amperage PH1	0	447	447	448	447	0
PH2	0	447	448	447	448	0
PH3	0	447	447	447	446	0
Kilowatts	0	170	170	170	170	0
Oil Pressure	52	50	50	50	50	51
Oil Temperature						
Coolant Temperature	184°F	195°F	195°F	195°F	196°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.9	13.9	13.9	13.9	13.9	13.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	58°F	58°F	58°F	58°F	59°F	59°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: _____

Customer Signature: _____