

# CHARLES EQUIPMENT ENERGY SYSTEMS

# LOAD BANK TESTING

Customer: Central States Diesel Generators CSDG STK#2246  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip: Waukesha/ WI/ 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 5141  
 Test Date: 4/5/2018

Engine Make/ Model: John Deere 6076TF010  
 Engine Spec/ Serial: RG6076T195971  
 Unit Make/ Model: Kohler 125ROZJ81  
 Unit Spec/ Serial: 351022

Voltage: 120/208  
 Amperage: 347  
 Kilowatts: 125  
 Power Factor: 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	217	217.2	217.5	217.7	218	218.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	210	210	210	210	210	210
PH2	210	210	210	210	210	210
PH3	209	209	209	209	209	209
Amperage PH1	0	347	347	346	347	0
PH2	0	346	347	347	346	0
PH3	0	346	346	346	346	0
Kilowatts	0	125	125	125	125	0
Oil Pressure	55	51	50	50	50	52
Oil Temperature						
Coolant Temperature	170°F	178°F	178°F	178°F	178°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.9	14.9	14.9	14.9	14.9	14.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	23°F	23°F	23°F	24°F	24°F	24°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: Randy P.

Customer Signature: \_\_\_\_\_