



Customer: Central States Diesel Generators STK#2247  
 Address: 2001 S Prairie Avenue  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 5424  
 Test Date 7/13/2018

Engine Make/ Model: Hino EK130  
 Engine Spec/ Serial: A10639  
 Unit Make/ Model: Generac 92A03164-S  
 Unit Spec/ Serial: 2004557

Voltage: 277/480  
 Amperage: 225  
 Kilowatts: 150  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	999.8	1000	1000.3	1000.5	1000.8	1000.9
Hertz/Cycles	60.4	60.4	60.4	60.4	60.4	60.4
Voltage PH1	480	480	480	480	479	480
PH2	481	480	479	480	480	481
PH3	481	480	480	481	480	481
Amperage PH1	0	180	180	181	181	0
PH2	0	181	181	180	180	0
PH3	0	181	181	181	181	0
Kilowatts	0	150	150	150	150	0
Oil Pressure	70	65	65	65	65	65
Oil Temperature						
Coolant Temperature	185°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.6	28.6	28.6	28.6	28.6	28.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	81°F	81°F	81°F	82°F	82°F	82°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_