

CHARLES EQUIPMENT ENERGY SYSTEMS

LOAD BANK TESTING

Customer: Central States Diesel Generators CSDG STK#2249
 Address: 2001 S Prairie Ave.
 City/ State/ Zip: Waukesha/ WI/ 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 5156
 Test Date: 4/10/2018

Engine Make/ Model: John Deere 6125AF001
 Engine Spec/ Serial: RG6125A015520
 Unit Make/ Model: Energy Now SED250FJJ4
 Unit Spec/ Serial: WA536487. 94145-1203

Voltage: 120/240
 Amperage: 601
 Kilowatts: 250
 Power Factor: 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	328	328:15:00	328:30:00	328:45:00	329	329:05:00
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	240	240	240	240	240	240
PH2	240	240	239	240	240	240
PH3	239	239	239	239	239	239
Amperage PH1	0	600	600	602	601	0
PH2	0	602	601	600	600	0
PH3	0	600	602	600	602	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	48	47	46	46	46	48
Oil Temperature						
Coolant Temperature	180°F	183°F	183°F	183°F	183°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.2	28.2	28.2	28.2	28.2	28.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	41°F	42°F	42°F	42°F	42°F	43°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy P.

Customer Signature: _____