



Customer: CSDG #2251  
 Address: \_\_\_\_\_  
 City/ State/ Zip: \_\_\_\_\_  
 Contact: \_\_\_\_\_  
 Phone: \_\_\_\_\_

R#: 5165  
 Test Date 4/13/2018

Engine Make/ Model: FORD WSG1068  
 Engine Spec/ Serial: E172A 271008 3010204 6P 680 AA  
 Unit Make/ Model: GENERAC QT15068JNSN  
 Unit Spec/ Serial: 5437623

Voltage: 240  
 Amperage: 450  
 Kilowatts: 150  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	103.9	104.2	104.5	104.7	104.9	105
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	239	240	239	239	240	240
PH2	240	240	240	240	240	240
PH3	240	240	240	240	240	240
Amperage PH1	150	355	355	355	357	0
PH2	154	359	359	359	359	0
PH3	155	361	361	361	361	0
Kilowatts	63	149	149	149	149	0
Oil Pressure	100	73	72	72	72	77
Oil Temperature						
Coolant Temperature	170°F	199°F	199°F	199°F	199°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.5	13.6	13.6	13.6	13.6	13.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	47°F	47°F	47°F	47°F	47°F	47°F

Cable Length: 25 \_\_\_\_\_

Cable/ Leg: 1 \_\_\_\_\_

Connection Point: GENERATOR BREAKER \_\_\_\_\_

Technician Signature: Rudy Aceves

Customer Signature: \_\_\_\_\_