



Customer: Central States Diesel Generators STK#2254  
 Address: 2001 S Prairie Avenue  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 5331  
 Test Date 5/7/2018

Engine Make/ Model: Volvo Penta TAD1232GE  
 Engine Spec/ Serial: 2120248305 VPH1611339  
 Unit Make/ Model: Katolight D350FRV4  
 Unit Spec/ Serial: WA516402 52912

Voltage: 277/480  
 Amperage: 527  
 Kilowatts: 350  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	335.9	336.1	336.4	336.6	336.9	337
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	484	485	485	485	485
PH2	485	485	485	485	485	485
PH3	485	485	484	484	485	485
Amperage PH1	0	418	419	417	417	0
PH2	0	417	417	418	418	0
PH3	0	418	418	418	417	0
Kilowatts	0	351	351	351	351	0
Oil Pressure	70	65	65	65	65	68
Oil Temperature						
Coolant Temperature	185°F	195°F	195°F	195°F	195°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	72°F	72°F	72°F	72°F	73°F	73°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_