



Customer: Central States Diesel Generators STK#2255
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5318
 Test Date 5/4/2018

Engine Make/ Model: Mitsubishi 6D24
 Engine Spec/ Serial: 292856
 Unit Make/ Model: Generac SD250
 Unit Spec/ Serial: 2050183

Voltage: 120/208
 Amperage: 694
 Kilowatts: 250
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	227	227.3	227.5	227.8	228	228.1
Hertz/Cycles	60.4	60.4	60.4	60.4	60.4	60.4
Voltage PH1	208	207	208	207	208	208
PH2	207	208	207	208	207	207
PH3	207	207	207	207	207	207
Amperage PH1	0	694	697	694	697	0
PH2	0	696	695	696	695	0
PH3	0	695	695	698	698	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	62	59	58	58	58	60
Oil Temperature						
Coolant Temperature	170°F	173°F	173°F	173°F	173°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.3	28.3	28.3	28.3	28.3	28.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	64°F	65°F	65°F	65°F	65°F	65°F

Cable Length: _____

Cable/ Leg: _____

Connection Point: _____

Technician Signature: Randy Pool

Customer Signature: _____