



Customer: Central States Diesel Generators STK#2261
 Address: 2001 S Prairie Avenue
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 5397
 Test Date 5/22/2018

Engine Make/ Model: MTU 12V4000
 Engine Spec/ Serial: 5262000763
 Unit Make/ Model: MTU
 Unit Spec/ Serial:

Voltage: 277/480
 Amperage: 1804
 Kilowatts: 1500 Prime/ 1650 Standby
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	1.5 Hours	2 Hours	2.5 Hours	3 Hours	Cool Down
Eng Hours	2319	2319	2319	2319	2320	2320	2320	2320	2321	2321
Hertz/Cycles	60	60	60	60	60	60	60	60	60	60
Voltage PH1	485	484	485	484	485	484	485	485	485	485
PH2	483	484	483	484	483	483	482	483	482	483
PH3	480	479	481	479	480	481	480	481	480	480
Amperage PH1	0	1798	1796	1798	1794	1799	1796	1795	1798	0
PH2	0	1796	1795	1795	1795	1795	1798	1798	1800	0
PH3	0	1796	1798	1793	1798	1794	1795	1796	1795	0
Kilowatts	0	1501	1503	1500	1501	1503	1503	1501	1503	0
Oil Pressure										
Oil Temperature										
Coolant Temperature	180°F	180°F	180°F	180°F	180°F	180°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B										
Man Vac./Press. R/B										
L/B Exhaust Temp										
R/B Exhaust Temp										
Exhaust Temperature										
DC Voltage	27	27	27	27	27	27	27	27	27	27
Natural Gas Pressure										
Diesel Fuel Level										
Room Temperature										
Ambient Temperature	73°F	73°F	73°F	73°F	73°F	73°F	73°F	73°F	74°F	74°F

Cable Length: _____ Cable/ Leg: _____ Connection Point: _____

Technician Signature: _____

Customer Signature: _____